



**DEVELOPMENTAL SPECIFICATIONS
FOR
BACKFILLING AND COMPACTION OF CULVERTS BY FLOODING**

**Effective Date
October 20, 2009**

THE STANDARD SPECIFICATIONS, SERIES 2009, ARE AMENDED BY THE FOLLOWING MODIFICATIONS AND ADDITIONS. THESE ARE DEVELOPMENTAL SPECIFICATIONS AND THEY SHALL PREVAIL OVER THOSE PUBLISHED IN THE STANDARD SPECIFICATIONS.

09024.01 DESCRIPTION

This specification describes backfill and compaction requirements for culverts using flooding. Apply Sections 2415, 2416 and 2417 of the Standard Specifications unless modified by this specification.

01120.02 MATERIALS

Use floodable backfill material meeting the requirements of Section 4134 of the Standard Specifications.

When required, use porous backfill material meeting the requirements of Section 4131 of the Standard Specifications.

09024.03 CONSTRUCTION

When backfilling and compaction by flooding is required, backfill may be placed in lifts up to 2 feet (0.6 m) thick. Determine if culverts need to be restrained and take appropriate actions to prevent floating of culverts during backfilling, flooding, and compaction.

Begin surface flooding for each lift at the inlet end of the culvert and progress to the outlet. To ensure uniform surface flooding and adequate compaction, fan-spray water in successive 6 to 8 foot (1.8 to 2.4 m) increments using a 2 inch (50 mm) diameter hose for three minutes within each increment. Run the hose fully, but with the water pressure low enough to avoid eroding cohesive soil plugs.

After flooding, evaluate the effectiveness of the compaction with a vibratory pan compactor. If the pan compactor produces visible compaction, repeat the flooding process until the pan compactor produces no visible compaction.

09024.04 METHOD OF MEASUREMENT

The quantity of Flooded Backfill, in cubic yards (cubic meters), will be the quantity shown in the contract documents regardless of the compaction method. The quantity measured for payment will not be adjusted unless the quantity of culvert installed is adjusted.

09024.05 BASIS OF PAYMENT

The Contractor will be paid the contract unit price for Flooded Backfill per cubic yard (cubic meters).

Backfill material, subdrains, restraining culverts against floating, and water required for flooding will not be measured separately for payment, but will be considered incidental to the contract unit price bid for Flooded Backfill.